1. Title	Design non-water-based fire systems and equipment
2. Code	EMFSDE502A
3. Range	Apply the expertise in fire system design; analyze, reorganize, assess and integrate information critically by dealing with abstract ideas, concepts and thoughts; instruct subordinates to perform different levels of tasks of designing non-water-based fire systems and equipment according to client needs, building codes and limitations.
4. Level	5
5. Credit	6
6. Competency	Performance Requirements
	 6.1 Knowledge of designing non-water-based fire systems and equipment, including: systems and equipment FM200 system NAFSIII system Other similar extinguishing agent system Understand building uses, architectural design codes and client needs Understand the design standards and major requirements of non-water-based fire systems and equipment, including: The Code of Practice for Fire Service Installations and Equipment Recognized international standards (BSEN, NFPA)
	 6.2 Design non-water- based fire systems and equipment Lead subordinates to perform various types of tasks of designing non-water-based fire systems and equipment according to client needs, manufacturer guidelines, recognized standards and relevant local regulations Formulate the system drawings and outline design layout plans of various types of equipment according to building codes and limitations Calculate and determine the performance requirements and the size of non-water-based systems and equipment according to building codes and limitations, including: Calculating gas volume Determining pipe diameter and nozzle size Number of containers Calculating other operation data of non-water-based systems and equipment Formulate the specifications of various types of non-water-based systems and equipment and select relevant equipment

	 6.3 Professionalism in designing non-water-based water-based systems and equipment Lead subordinates to design non-water-based fire systems and equipment according to legal requirements, codes of practice and design standards
7. Assessment Criteria	 The integrated outcome requirements of this unit of competency are: (i) Capable to apply special and innovative techniques and lead subordinates to perform tasks of designing non-water-based fire systems and equipment according to client needs and building codes and limitations; and (ii) Capable to provide the sector and clients with designs of non-water-based fire systems and equipment.
8. Remarks	The credit value of this unit of competency is set on the presumption that the person already possesses general knowledge of non-water-based fire systems and equipment.