

1. Title	Handle LPG vehicle failure safely	
2. Code	EMGAOM301A	
3. Range	Handle urgent failures of LPG vehicles, such as failure of parts, gas leakage and fire outbreak, in the LPG filling station to avoid affecting the filling station operation or causing more serious accident.	
4. Level	3	
5. Credits	4	
6. Competency	<p style="text-align: center;"><u>Performance Requirements</u></p> <p>6.1 Knowledge and principles of handling LPG vehicle failure safely</p> <ul style="list-style-type: none"> ◆ Understand the whole gas supply system of LPG vehicle ◆ Understand the whole LPG filling station system ◆ Master general fire safety knowledge ◆ Use dry powder fire extinguisher correctly <p>6.2 Methods and procedures of handling LPG vehicle failure safely</p> <ul style="list-style-type: none"> ◆ Press the emergency shut-down button correctly to stop the operation of the whole LPG filling station system ◆ Judge the seriousness of the LPG vehicle failure and its influence on the filling station, and take necessary steps to handle it ◆ Close input and output valves correctly ◆ Inform departments concerned correctly to follow up ◆ Control the on-site situation <p>6.3 Professional knowledge and responsibilities for handling LPG vehicle failure safely</p> <ul style="list-style-type: none"> ◆ Apply other gas related regulations and codes of practice 	

7. Assessment Criteria	The integrated outcome requirement of this unit of competency is: (i) Capable to handle urgent failures of LPG vehicles, such as failure of parts, gas leakage and fire outbreak, in the LPG filling station to avoid affecting the filling station operation or causing more serious accident.
8. Remarks	The credit value of this unit of competency is set on the presumption that the person already possesses the competency of EMGADE101A 【Basic knowledge of gas application】 .