

| | |
|------------------------|---|
| 1. Title | Install general plastic pipes and fittings |
| 2. Code | EMCUIN216A |
| 3. Range | Perform simple installation of general plastic (e.g. PVC,ABS and UPVC) pipes and fittings, and common parts at general industrial plants, power plants or premises/work sites where boat, fire fighting, water, gas or pipe works is involved. |
| 4. Level | 2 |
| 5. Credits | 3 |
| 6. Competency | <p style="text-align: center;"><u>Performance Requirements</u></p> <p>6.1 Types of pipes and fitting materials</p> <ul style="list-style-type: none"> ◆ Know about the types of pipes, accessories and materials, including: <ul style="list-style-type: none"> • Types of pipes • Bends and tees • Extension joints • Joint accessories • Fill materials • Bedding and coating materials ◆ Understand hazards of solvent cement to individuals and the environment <p>6.2 Methods of installing and jointing pipes</p> <ul style="list-style-type: none"> ◆ Capable to apply general repairing and bench fitting techniques in pipe installation according to requirements ◆ Capable to joint pipes by solvent cement, etc. ◆ Capable to apply common methods of cold or thermal bending in simple installation of pipes ◆ Place rubber gaskets or pads at proper positions to prevent leakage <p>6.3 Professionalism in pipe overhaul and installation</p> <ul style="list-style-type: none"> ◆ Capable to use correct tools in simple installation of plastic pipes according to requirements ◆ Perform pipe installation according to legal requirements and the code of safety; pass the leakage test |
| 7. Assessment Criteria | <p>The integrated outcome requirement of this unit of competency is:</p> <p>(i) Capable to install common plastic pipes and fittings correctly and safely according to pipe-laying and legal requirements and the code of safety; pass the leakage test.</p> |
| 8. Remarks | The credit value of this unit of competency is set on the presumption that the person already possesses basic knowledge of mechanics and installation skills. |